



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No:** 3774-1175:101

Page 1 of 1

**CATEGORY:** Electric Locks

**LISTEE:** Best Access Systems, 6161 E. 75<sup>th</sup> Street, Indianapolis, IN 46250  
Contact: Robert Strong (317) 849-2250

**DESIGN:** Models 30HEL and 30HEU with 3/4" latch bolt mortise type rated 24 VDC;  
Models 34HV\* and 35HV\* with 3/4" latch throw mortise type battery  
operated. Refer to listee's data sheet for detailed product description and  
operational considerations.

**RATING:** 24 VDC or Battery

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and  
ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as electrically controlled single point locks or latches suitable for fire-  
rated doors. Authority having jurisdiction shall be consulted prior to  
installation.

**NOTE:** Formerly 4136-1175:101



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test result and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

\*Rev. 12-04-2000

Date Issued: **DECEMBER 4, 2000**

Effective issue date to expiration date

**Listing Expires June 30, 2001**

Authorized By:

BEN HO, *Supervising Deputy*  
*Program Manager*