



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No: 3774-1175:103

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Best Access Systems, 6161 E. 75th Street, Indianapolis, IN 46250
 Contact: Robert Strong (317) 849-2250

DESIGN: Models 8KDEL, 8KDEU with a 9/16" or 3/4" latch bolt rated 24 VDC;
 Models 9KDEL, 9KDEU with a 9/16" or 3/4" latch bolt ~~mortise type locks~~
 rated 24 VDC; Models 83KV*, 84KV*, 85KV*, 93KV*, 94KV* and 95KV*
 battery operated with a 9/16" or 3/4" latch bolt electronic cylindrical type
 locks. Suffix -DEL indicating fail-safe and -DEU indicating fail-secure. Refer
 to listee's data sheet detailed product description and operational
 considerations.

RATING: 24 VDC or Battery

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes
 and ordinances and in a manner acceptable to the authority having
 jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as electrically controlled single point locks or latches suitable for fire-
 rated doors. Authority having jurisdiction shall be consulted prior to
 installation.

NOTE: Formerly 4136-1175:103

*Rev. 12-04-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 4, 2000**
 Effective issue date to expiration date

Authorized By:

BEN HO, *Supervising Deputy*
 Program Manager

Listing Expires June 30, 2001