



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No: 3774-1175:104

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Best Access Systems, 6161 E. 75th Street, Indianapolis, IN 46250
Contact: Robert Strong (317) 849-2250

DESIGN: Model IDH Max Access Control System. The system consists of other existing listed lock hardware, Model 30HW (CSFM Listing No. 4136-1175:101), 8KW or 9KW (CSFM Listing No. 4136-1175:103). Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as an access control system for use on swinging type fire doors. Authority having jurisdiction shall be consulted prior to installation.

12-04-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test result and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 4, 2000**
Effective issue date to expiration date

Authorized By:

BEN HO, *Supervising Deputy*
Program Manager

Listing Expires June 30, 2001